

# INSTALLATION INSTRUCTIONS

- 1.) Install service shut-off valve in water supply line (valve not supplied).
- 2.) Remove the (8) 1/4-20 x 3/4" security screws holding the access panel onto the fixture and disconnect the blue pneumatic line from the push button.
- 3.) Remove the (8) 1/4-20 x 3/4" security screws along the side of the fixture to remove front of the fixture from the back plate, keeping the (8) tinnermen clips in place. Disconnect the 3/8" line from the valve to the PTC fitting in the bubbler.
- 4.) Install the bottle filler back panel. Make sure that the positioned fixture back plate is level side to side, to ensure proper draining. Adjust as necessary, then fully tighten the screws to secure the fixture (mounting hardware not supplied).
- 5.) Flush the water supply line with clean drinking water before making final connections to the 1/2" F.I.P. bottle filler valve supply.
- 6.) Place the front of the fixture back on the back plate and using (8) of the 1/4-20 x 3/4" security screws. Reconnect the 3/8" line from the valve to the PTC fitting in the bubbler.
- 7.) Connect the drain to drainage system. The drain is 1-1/2" F.I.P. and is to be connected to a P-trap (P-trap not supplied)
- 8.) Turn on water supply and check both the water supply lines and drain lines for leaks.
- 9.) Hook the blue pneumatic line back up to the pushbutton and using the last (8) 1/4-20 x 3/4" security screws replace the access panel.

